

ABOVE GROUND TANK DESIGN

Test Certificate

Issued pursuant to Section 82 of the Hazardous Substances and New Organisms Act 1996

NAME: Civilquip NZ Limited

ADDRESS : 54 Tasman Street
Greymouth
Ph 03 768 9681

CERTIFICATE NO. 141
TANK ID: EBD2000
EQUIPMENT # : NA
CLIENT FILE # : 10087

TANK CONSTRUCTION CODE: AS 1692 - 2006, Category 3
CAPACITY : 10,450 litres
MANUFACTURE YEAR : Nameplate

DATE ISSUED : 24/02/2011

EXPIRY DATE : N/A

Unless surrendered or revoked, this certificate remains valid for the service life of the tank.

This Certificate certifies that the prescribed requirements of the Regulations under the Hazardous Substances and New Organisms Act 1996 listed below have been met.

Approved for :

The storage and transfer of diesel having a hazard classification of 3.1D, 6.1E, 6.3B, 6.7B, 9.1B

Subject To :

Compliance with AS 1692-2006 and approved Civilquip Drawings No. EBD2000-001-01 to 120 Incl.



Graham Voss

Test Certifier Registration No : TST000083

This certificate is issued subject to the condition that it must be able to be produced when required by an Enforcement Officer appointed under the HSNO Act 1996.

Tank Inspection and Certification
Limited
152A Brooklands Road
New Plymouth, 4310
New Zealand